


HEXCEL

SDMS Document



88543



August 30, 1990

Mr. Karl J. Delaney, Assistant Director
Industrial Site Evaluation Element
Division of Hazardous Waste Management
State of New Jersey Department of Environmental Protection
CN 028
Trenton, NJ 08625-0028

Re: Former Hexcel Corporation Facility, 205 Main Street, Lodi, NJ
ECRA Case # 86009

Dear Mr. Delaney:

This letter is written in response to Item Number 29 of your July 31, 1990, Cleanup Plan approval letter concerning inspection and registration of the three underground storage tanks (USTs) located on the above-referenced property. The specific requirements of your approval letter that this letter addresses are as follows:

- "Hexcel Corp. shall submit, within 30 days of this approval, documentation (i.e., inspection results) that proves the three underground storage tanks are completely empty..."
- "Within 30 days from receipt of this approval register all underground storage tanks on site with NJDEP Bureau of Underground Storage Tanks..."

Our environmental consultant, ENVIRON International Corporation ("ENVIRON") visited the facility on August 21, 1990, to inspect the three underground storage tanks. A visual inspection of the tanks indicated that the tanks are not completely empty. ENVIRON'S observations concerning the contents of each UST during the August 21st inspection are summarized as follows:

- 250 gallon gasoline tank: The tank contained approximately one foot of fluid having physical characteristics (visual and odor) similar to groundwater observed in the surrounding wells.


Mr. Karl J. Delaney
August 30, 1990
Page 2

- 2,000 gallon fuel oil tank: The tank contained approximately 1.25 feet of ground water and oily sludge. A sheen was observed on the water surface.
- 4,000 gallon fuel oil tank: The tank contained approximately 1.5 feet of groundwater and oily sludge. A sheen was observed on the water surface.

As shown on the enclosed Underground Storage Tank Registration Certificate, the three onsite USTs have been registered with the NJDEP Bureau of Underground Storage Tanks under UST No. 0058214. The effective date of registration is March 1, 1990, and the expiration date is February 28, 1991.

We trust that the information provided in this letter addresses the issues described in the approval letter. Please do not hesitate to call if you have questions or require additional information.

Sincerely yours,



A. William Nosil
Corporate Environmental Engineering Manager

AWN\lr

Enclosure

cc: John Schroeter- Environ
Joe Ritchey-Heritage
Jim Higdon- Fine Organics

885430002

LAST MODIFIED 3/10/91



Underground Storage Tank

Registration Certificate

FINE ORGANICS CORP
205 MAIN ST
LODI, NJ 07644

DIVISION OF WATER RESOURCES
BUREAU OF UNDERGROUND STORAGE TANKS
CN 029
TRENTON, NEW JERSEY 08625

UST No. 0058214

The above listed facility has complied with P.L. 1986,c.102 and has duly registered with the NJDEP.
(Facility name and location if different than above)

NAME: FINE ORGANICS CORPORATION
ADDRESS: 205 MAIN ST
LODI, NJ 07644

PRODUCT(S) LEADED GASOLINE
STORED: HEATING OIL (NO. 4)

ON-SITE MANAGER: JAMES R HIGDON
TELEPHONE: (201)472-6800
NO. OF TANKS: 3

EFFECTIVE DATE: 03/01/90

EXPIRATION DATE: 02/28/91

RC3 (3/89)

THIS FORM MUST BE AVAILABLE FOR INSPECTION AT THE FACILITY AT ALL TIMES

New Jersey Department of Environmental Protection

885430003